

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013736-R1
DATE: 06/01/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 11/01/2021
EXPIRATION DATE: 06/30/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Seves Glass Block, Inc. 10576 Broadview Road Broadview Heights, OH 44147	Series "Endura Thickset 90" Fire-Rated Glass Block Manufacturer Specific Glass Blocks for Installation in 90 Minute Locations Max Opening: 100ft ² or W-122" or H-121" Glass Block Weight: 10.0 lb Glass Block Size: 7.75" x 7.75" Minimum Thickness: 3.88"

SPECIFICATION	PRODUCT RATING
ANSI/UL 9	90 Minutes With Hose Stream

TEST REPORT
Underwriters Laboratory Test Report No: R2556 92NK19281

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122