

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013767-R3  
DATE: 06/28/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Seves Glass  
CODE: 2322-1  
REVISION DATE: 01/08/2025  
EXPIRATION DATE: 06/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Seves Glass Block S.R.O.</b> <b>Bilinská 782/42</b> <b>Duchcov, 419 01, Czech Republic</b>	<b>Series "VistaBrik"</b> <b>Fire-Rated Solid Glass Block</b> Manufacturer Specific Glass Blocks for Installation in 90 Minute Locations  Max Opening: 100ft <sup>2</sup> or W-120" or H-121"  Glass Block Weight: 15.6 lb <b>Glass Block Size: 7.63" x 7.63"</b> <b>Minimum Thickness: 3"</b>

SPECIFICATION	PRODUCT RATING
<b>ANSI/UL 9</b>	<b>90 Minutes</b> <b>With Hose Stream</b>

TEST REPORT
<b>Underwriters Laboratory Test Report No: R2556 02NK10299/R2556 92NK19281</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023