

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013767-R2
DATE: 06/28/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Seves Glass
CODE: 2322-1
REVISION DATE: 04/29/2024
EXPIRATION DATE: 06/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Seves Glass Block, Inc. 10576 Broadview Road Broadview Heights, OH 44147	Series "VistaBrik" Fire-Rated Solid Glass Block Manufacturer Specific Glass Blocks for Installation in 90 Minute Locations Max Opening: 100ft ² or W-120" or H-121" Glass Block Weight: 15.6 lb Glass Block Size: 7.63" x 7.63" Minimum Thickness: 3"

SPECIFICATION	PRODUCT RATING
ANSI/UL 9	90 Minutes With Hose Stream
TEST REPORT	
Underwriters Laboratory Test Report No: R2556 02NK10299/R2556 92NK19281	

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023

